03_Fire Extinguisher Schedule							
Keynote	Family	F.E. Diameter(mm)	F.E. Gross Weight	F.E. Height(mm)	F.E. Mounting Height(mm)	F.E. Test Pressure	Notes
10 44 16.13.A	Fire Extinguisher	120	8.10 kg	380	800	25000000.0 Pa	n/a

Grand total: 13

04_Fire Department Inlet Connection Schedule						
Keynote	Family	F.I.-Material	F.I. Inlet(mm)	F.I. No. of Inlets	Hosted Level	Notes
21 11 19.A	Fire Department Inlet Connection - 3 Way - Flush Plate	Polished Brass Plate	89	3	Level 1	n/a

Grand total: 1

05_Sprinkler Schedule					
Keynote	Family	S. Diameter(mm)	S.Depth(mm)	Temp. Rating	Notes
21 13 13.A	Sprinkler - Dry - Pendant - Hosted	15	98	57 °C	n/a
76					
21 13 13.B	Sprinkler - Dry - Horizontal Sidewall - Hosted	15	98	57 °C	n/a
9					

Grand total: 85

06_Fire Alarm Control Panel Schedule							
Keynote	Family	F.A.Width(mm)	F.A. Depth(mm)	F.A. Height(mm)	Panel Name	Voltage	Notes
28 31 23.A	Fire Alarm Control Panel	400	138	475	FACP-01	220 V	n/a

Grand total: 1

07_Heat Detector Schedule							
Keynote	Family	H.D. Diameter	H.D. Depth	Voltage	Power	H.D. Fixed Temp.	Notes
28 31 43.A	Heat Detector	150	50	24 V	0.2 W	58 °C	n/a

Grand total: 3

08_Smoke Alarm Schedule							
Keynote	Family	S.D. Diameter(mm)	S.D. Depth(mm)	Voltage	Power	S.D.Operating Temperature	Notes
28 31 46.A	Smoke Alarm	150	50	24 V	0.2 W	38 °C	n/a

Grand total: 35

09_Fire Alarm Break Glass Unit Schedule							
Keynote	Family	B.G.U. Width(mm)	B.G.U. Height(mm)	B.G.U. Depth(mm)	Voltage	Power	Notes
28 31 53.13.A	Fire Alarm Break Glass Unit	88	88	50	24 V	0.12 W	n/a

Grand total: 10

10_Fire Alarm Sounder Schedule							
Keynote	Family	F.A.S. Diameter(mm)	F.A.S. Depth(mm)	F.A.S. Audio Level	Voltage	Power	Notes
28 31 63.13.A	Fire Alarm Sounder	150	51	75 dB	24 V	0.6 W	n/a

Grand total: 25

THIS DESIGN IS NOT INTENDED TO MEET THE BUILDING CODES OR REGULATIONS OF ANY SPECIFIC COUNTRY OR JURISDICTION.

SOME COMPONENTS HAVE BEEN OMITTED AS THE DESIGN WAS MODELLED EXCLUSIVELY USING OUT OF THE BOX REVIT FAMILIES.

MMA ENVIRONMENTAL
M&E Consulting Engineers

4E Fingal Bay Business Park
Balbriggan
Co. Dublin
K32 HN82
Ireland

Email: info@mma.ie
Phone: +353 1 6905040
Web: www.mma.ie

ACEI ASSOCIATION OF CONSULTING ENGINEERS OF IRELAND

Four Dormitory Complex
East Healey Street,
Champaign,
Illinois,
USA

Prairie Sky Consulting

1104 Parkview Drive
Mahomet
Illinois
USA 61853

Email: bill.east@prairieskyconsulting.com
Phone: 309 - 807 - 1519
Web: www.prairieskyconsulting.com/

REV	DATE	DESCRIPTION
5	21.07.17	Final Issue
4	04.07.17	Spaces Revised
3	20.06.17	Keynotes Revised
2	31.06.17	Issued for 2nd Review
1	26.05.17	Issued for Review

PROJECT NUMBER	East Dormitory
DRAWN BY	R.K.
CHECKED BY	B.E.
SCALE (@ A1)	
DATE	05/23/17
STATUS	Final Issue
REVISION	5

PROJECT

Four Dormitory Complex

TITLE

Fire Protection Items - Schedules

F-601

SHEET 4 OF 4

THIS DRAWING IS THE PROPERTY OF MMA ENVIRONMENTAL AND SHALL NOT BE USED, REPRODUCED OR DISCLOSED TO ANYONE WITHOUT THE PRIOR WRITTEN PERMISSION OF MMA ENVIRONMENTAL.

21/07/2017 15:08:29